

## 2024 Annual Drinking Water Quality (Testing Performed January through December 2023)

### NORTH DALLAS COUNTY WATER AUTHORITY

PWSID AL0000482  
7590 Alabama Highway 22  
Selma, AL 36701  
Phone 334-872-4966  
Fax 334-872-0943

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

<b>Water Sources</b>	Four groundwater wells producing from the Coker and Gordo aquifers
<b>Water Treatment</b>	Chlorination, iron and manganese removal, and corrosion control
<b>Storage Capacity</b>	Seven tanks with a total capacity of 1,700,000 gallons
<b>Booster Pumping Stations</b>	County Road 81 and Alabama Highway 22
<b>Number of Customers</b>	Approximately 2920
<b>Board Members</b>	Tommy Morris, Chairman
	Dave Davis, Member
	David Smith, Member
	Shaudonna Minor, Member
	Ronald McWilliams, Member
<b>Manager/Operator</b>	Hart Sims
<b>Operator</b>	Richard Rembert

### Water Quality Protection

In compliance with the Alabama Department of Environmental Management (ADEM), North Dallas County Water Authority has developed a Source Water Assessment plan that will assist in protecting our water sources. The assessment has been performed, public notification has been completed, and the plan has been approved by ADEM. All of the potential contaminants sited in our study area were ranked as non-susceptible or low risk to our water supply. A copy of the report is available in our office for review during regular business hours, or you may purchase a copy upon request for a nominal reproduction fee.

North Dallas County Water Authority routinely completes a water storage facility inspection plan and utilizes a Bacteriological Monitoring Plan. The required chlorine residual is maintained throughout our distribution system to protect your drinking water from possible outside contaminants. We have also established a Cross-Connection Policy to insure safe drinking water for our customers. Please help us make these efforts worthwhile by protecting our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden, and properly dispose of household chemicals, paints, and waste oil. We ask that all our customers help us protect our valuable water sources, which are the heart of our community, our way of life, and our children's futures.

### Information about Lead

Lead in drinking water is rarely found in source water but is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Use *only* water from the cold-water tap for drinking, cooking, and *especially for making baby formula*. Hot water is more likely to cause leaching of lead from plumbing materials. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. These recommended actions are very important to the health of your family.

Lead levels in your drinking water are likely to be higher if:

- Your home or water system has lead pipes, or
- Your home has faucets or fittings made of brass which contains some lead, or
- Your home has copper pipes with lead solder and you have naturally soft water, and
- Water often sits in the pipes for several hours.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## **General Information**

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. MCL's, defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the levels of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immunocompromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

## **Questions?**

If you have any questions about this report or concerning your water utility, please contact Hart Sims at 334-872-4966. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at the water office at 5:00 pm.

More information about contaminants to drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

## **Monitoring Schedule and Results**

The Alabama Department of Environmental Management (ADEM) allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. This report contains results from the most recent monitoring which was performed in accordance with the regulatory schedule.

<b>Constituent Monitored</b>	<b>Date Monitored</b>
Inorganic Contaminants	2023
Lead/Copper	2023
Microbiological Contaminants	monthly
Nitrates	2023
Radioactive Contaminants	2023
Synthetic Organic Contaminants (including pesticides and herbicides)	2023
Volatile Organic Contaminants	2023
Disinfection By-products	2023
PFAS Contaminants	2021

As you can see by the table below, our system had no MCL violations. We have learned through our monitoring and testing that some constituents have been detected. We are pleased to report that our drinking water meets federal and state requirements. This report shows our water quality and what it means.

TABLE OF DETECTED DRINKING WATER CONTAMINANTS						
Contaminants	Violation Y/N	Level Detected	Unit Msmt	MCLG	MCL	Likely Source of Contamination
Alpha emitters	NO	6.30	PCi/l	0	15	Erosion of natural deposits
Combined radium (radium-228)	NO	2.8	PCi/l	0	5	Erosion of natural deposits
Barium	NO	0.049	ppm	2	2	Discharge from drilling wastes and metal refineries; erosion
Copper	NO	0.680 **	ppm	1.3	AL=1.3	Household plumbing corrosion; erosion; preservative leaching
Fluoride	NO	0.16	ppm	4	4	Erosion; water additive for teeth; discharge from fertilizer and aluminum factories
Lead	NO	0.001 **	ppm	0	AL=0.015	Household plumbing corrosion, erosion
Nitrate (as Nitrogen)	NO	ND-0.06	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Secondary Contaminants</b>						
Chloride	NO	5.5	ppm	n/a	250	Naturally occurring in the environment or from runoff
Hardness	NO	42.5	ppm	n/a	n/a	Naturally occurring or from water additives
Iron	NO	0.37	ppm	none	0.30	Naturally occurring; erosion; leaching from pipes
Manganese	NO	0.10	ppm	n/a	0.05	Erosion of natural deposits; leaching from pipes
pH	NO	7.2	S.U.	n/a	n/a	Naturally occurring or from water additives
Sodium	NO	5.2	ppm	none	none	Naturally occurring in the environment
Total Dissolved Solids	NO	92.0	ppm	n/a	500	Naturally occurring in the environment or from runoff
Zinc	NO	0.30	ppm	none	5	Erosion; refinery and factory discharge; landfill runoff

\* Figure shown is 90<sup>th</sup> percentile and number of sites above the Action Level (AL) = 0

#### PFAS Contaminants

Per- and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals that were used in the manufacture of nonstick cookware, stain-resistant carpet and textiles, and other industrial and consumer applications. Below is a list of PFAS contaminants for which our system monitored in 2021 as required and the results of that monitoring. *PFAS was not detected in our drinking water.* For more information on PFAS contaminants, please consult [www.epa.gov/pfas](http://www.epa.gov/pfas).

Contaminant	Unit Msmt	Level Detected	Contaminant	Unit Msmt	Level Detected
11CI-PF3OUdS (11-chloroeicosfluoro-3-oxaundecane-1-sulfonic acid)	ppb	ND	Perfluoroheptanoic acid	ppb	ND
9CI-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid)	ppb	ND	Perfluorohexanesulfonic acid	ppb	ND
ADONA (4,8-dioxa-3H-perfluorononanoic acid)	ppb	ND	Perfluorononanoic acid	ppb	ND
HFPO-DA (Hexafluoropropylene oxide dimer acidA)	ppb	ND	Perfluorooctanesulfonic acid	ppb	ND
NEtFOSAA (N-ethylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorooctanoic acid	ppb	ND
NMeFOSAA (N-methylperfluorooctanesulfonamidoacetic acid0	ppb	ND	Perfluorotetradecanoic acid	ppb	ND
Perfluorobutanesulfonic acid	ppb	ND	Perfluorotridecanoic acid	ppb	ND
Perfluorodecanoic acid	ppb	ND	Perfluoroundecanoic acid	ppb	ND
Perfluorohexanoic acid	ppb	ND	Total PFAS	ppb	ND
Perfluorododecanoic acid	ppb	ND			

## Definitions

Action Level- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Absent (ca)- Laboratory analysis indicates that the contaminant is not present.

Cryptosporidium- a microscopic parasite that can cause disease, mainly diarrhea, if swallowed.

Disinfection byproducts (DBPs)- are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water.

Distribution System Evaluation (DSE)-a 4-quarter study to identify distribution system locations with high concentrations of DBPs.

Maximum Contaminant Level (MCL) is the highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG)- the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)-the highest level of a disinfectant allowed in drinking water

Maximum Residual Disinfectant Level Goal (MRDLG) the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Millirems per year (mrem/yr)-measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU)-a measure of the clarity of water.

Non-Detect (ND)- laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Parts per billion (ppb) or Micrograms per liter ( $\mu\text{g/l}$ )-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter ( $\text{mg/l}$ )-one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)-one part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)-one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/l)-picocuries per liter is a measure of the radioactivity in water.

Running Annual Average (LRAA)-yearly average of all the DPB results at each specific sampling site in the distribution system.

Standard Units (S.U.)-pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas.

Treatment Technique (TT)- a required process intended to reduce the level of a contaminant in drinking water.

Variances & Exemptions (V&E)-State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Below is a table of contaminants for which the Environmental Protection Agency and the Alabama Department of Environmental Management require testing where applicable. These contaminants were not detected in your drinking water unless they are also listed in the Detected Drinking Water Contaminants table elsewhere in this report.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
<b>Bacteriological Contaminants</b>					
Total Coliform Bacteria	<5%	present/absent	cis-1,2-Dichloroethylene	70	ppb
Fecal Coliform and E. coli	0	present/absent	trans-1,2-Dichloroethylene	100	ppb
Turbidity	TT	NTU	Dichloromethane	5	ppb
Cryptosporidium	TT	Calc.organisms/l	1,2-Dichloropropane	5	ppb
<b>Radiochemical Contaminants</b>					
Beta/photon emitters	4	mrem/yr	Di (2-ethylhexyl)adipate	400	ppb
Alpha emitters	15	pCi/l	Di (2-ethylhexyl)phthalate	6	ppb
Combined radium	5	pCi/l	Dioxin [2,3,7,8-TCDD]	30	ppq
Uranium	30	pCi/l	Diquat	20	ppb
<b>Inorganic Chemicals</b>					
Antimony	6	ppb	Endothall	100	ppb
Arsenic	10	ppb	Endrin	2	ppb
Asbestos	7	MFL	Epichlorohydrin	TT	TT
Barium	2	ppm	Ethylbenzene	700	ppb
Beryllium	4	ppb	Ethylenedibromide	50	ppt
Cadmium	5	ppb	Glyphosate	700	ppb
Chromium	100	ppb	Heptachlor	400	ppt
Copper	AL=1.3	ppm	Heptachlor epoxide	200	ppt
Cyanide	200	ppb	Hexachlorobenzene	1	ppb
Fluoride	4	ppm	Hexachlorocyclopentadiene	50	ppb
Lead	AL=15	ppb	Lindane	200	ppt
Mercury	2	ppb	Methoxychlor	40	ppb
Nitrate	10	ppm	Oxamyl [Vydate]	200	ppb
Nitrite	1	ppm	Polychlorinated biphenyls	0.5	ppb
Selenium	.05	ppm	Pentachlorophenol	1	ppb
Thallium	.002	ppm	Picloram	500	ppb
<b>Organic Contaminants</b>					
2,4-D	70	ppb	Simazine	4	ppb
Acrylamide	TT	TT	Styrene	100	ppb
Alachlor	2	ppb	Tetrachloroethylene	5	ppb
Atrazine	3	ppb	Toluene	1	ppm
Benzene	5	ppb	Toxaphene	3	ppb
Benzo(a)pyrene [PAHs]	200	ppt	2,4,5-TP [Silvex]	50	ppb
Carbofuran	40	ppb	1,2,4-Trichlorobenzene	.07	ppm
Carbon tetrachloride	5	ppb	1,1,1-Trichloroethane	200	ppb
Chlordane	2	ppb	1,1,2-Trichloroethane	5	ppb
Chlorobenzene	100	ppb	Trichloroethylene	5	ppb
<b>Disinfectants &amp; Disinfection Byproducts</b>					
Dalapon	200	ppb	Chlorine	4	ppm
Dibromochloropropane	200	ppt	Chlorine Dioxide	800	ppb
1,2-Dichlorobenzene	1000	ppb	Chloramines	4	ppm
1,4-Dichlorobenzene (para)	75	ppb	Bromate	10	ppb
o-Dichlorobenzene	600	ppb	Chlorite	1	ppm
1,2-Dichloroethane	5	ppb	HAA5 [Total haloacetic acids]	60	ppb
1,1-Dichloroethylene	7	ppb	TTHM [Total trihalomethanes]	80	ppb
<b>LIST OF SECONDARY CONTAMINANTS</b>					
Alkalinity, Total (as Ca, Co <sub>3</sub> )	Copper		Manganese		Specific Conductance
Aluminum	Corrosivity		Odor		Sulfate
Calcium, as Ca	Foaming agents (MBAS)		Nickel		Total Dissolved Solids
Carbon Dioxide	Hardness		pH		Zinc
Chloride	Iron		Silver		
Color	Magnesium		Sodium		
<b>LIST OF UNREGULATED CONTAMINANTS</b>					
Aldicarb	Chloroethane		Dieldrin		Propachlor
Aldicarb Sulfone	Chloroform		Hexachlorobutadiene		N-Propylbenzene
Aldicarb Sulfoxide	Chloromethane		3-Hydroxycarbofuran		Propachlor
Aldrin	O-Chlorotoluene		Isopropylbenzene		1,1,1,2-Tetrachloroethane
Bromoacetic Acid	P-Chlorotoluene		p-Isopropyltoluene		1,1,2,2-Tetrachloroethane
Bromobenzene	Dibromochloromethane		M-Dichlorobenzene		Tetrachloroethene
Bromochloromethane	1,2-Dibromoethane		Methomyl		Trichloroacetic Acid
Bromodichloromethane	Dibromomethane		Methylene chloride		1,2,3-Trichlorobenzene
Bromoform	1,1-Dichloroethane		Methyl tert-butyl ether		Trichloroethene
Bromomethane	1,3-Dichloropropane		Metolachlor		Trichlorofluoromethane
Butachlor	2,2-Dichloropropane		Metribuzin		1,2,3-Trichloropropane
N-Butylbenzene	1,1-Dichloropropene		MTBE		1,2,4-Trimethylbenzene
Sec-Butylbenzene	1,3-Dichloropropene		Naphthalene		1,3,5-Trimethylbenzene
Tert - Butylbenzene	Dicamba		1-Naphthol		
Carbaryl	Dichlorodifluoromethane		Paraquat		